

Professional Startup Services (PROSTART)

Environmental
Consulting, Engineering
Process Startups &
Contract Operations

3414 Baywood Dr.
Forest Hill, MD
410-608-0885

Notice of Non-Compliance

Report to: Maryland Department of the Environment
Waste Management Administration
Compliance and Enforcement
1800 Washington Boulevard, Suite 420
Baltimore, MD 21230

Date: 12/28/19

Phone: 410-537-3510

Permittee: Maryland Manor MHC LLC
2138 Esprey Ct. Suite 1
Crofton MD. 21114

Permit #12-DP-0811
Outfall 001: Plant Effluent

1. Description of noncompliance: A) Ortho-Phosphate: A) OP: Not sampled in November 2019
2. Cause of noncompliance: A) Ortho-phosphate not sampled
3. Anticipated time the condition is expected to continue: A) November only:
4. Steps taken to reduce and eliminate non-complying discharge. A) Notified operations staff of OP sampling requirement in addition to TP:
5. Steps taken to prevent recurrence of condition of noncompliance: See No. 4 above.
6. Description of additional monitoring: A) Posted permit sampling requirements at facility:

Submitted by:
Jack Bradshaw
VP Operations: ProStart

Cc: Bill Farrell, President, PROSTART
Cc: Kate Costello: VP Operations HLC